



## Requirements for Inspection

This document is provided to assist with questions or concerns regarding plan review, fire & life safety features and/or what may be required at the final acceptance inspection as prescribed by Denton County.

Please review all of your approved plans and documents received from Denton County. Contained in these documents and drawings are guidelines and information for a successful acceptance test. In addition, always refer to your IBC & IFC for guide and familiarize yourself with the Denton County Codes which can be found on our website [www.dentoncounty.com/Departments/Emergency-Services/Emergency-Services](http://www.dentoncounty.com/Departments/Emergency-Services/Emergency-Services)

### **Required On-Site at Final Inspection**

- a. All Construction Approved & Stamped Drawings from Denton County
- b. Labeling & Door Identification (Electrical, Mechanical, Sprinkler Riser, Fire Alarm Control Panel, Room etc.)
- c. Building or Suite Address on Front & Back Doors (where applicable)
- d. Emergency Exit Door Identification and Locking Requirements (Lock Indicator, Panic Bar, etc.)
- e. Exit and Emergency Light Illumination
- f. Fire Wall Marking and Integrity " \_\_\_\_ HOUR FIRE AND SMOKE WALL...PROTECT ALL PENETRATIONS"
- g. Electrical Work and Workmanship (open boxes, panel labeling, securing raceways, switch covers, etc.)
- h. GFCI & ARC Fault Protection throughout (where applicable)
- i. Clearance Around Electrical and Life Safety Systems and Housekeeping Issues
- j. Fire Lane Marking and other Fire Service Features (where required)
- k. All Vendors Approved & Stamped Drawings (Sprinkler, Fire Alarm, Hood Suppression, etc.) from P.I.D.
- l. All Vendors Valid Licenses and Proof of I.D.
- m. Hand Portable Extinguishers (Size & Placement)
- n. Knox Box location, installation and size compliance at the sprinkler riser room, main entrance & elevator lobbies (where applicable)
- o. Sprinkler Work (if applicable) with SFMO Material Certification Forms (SF-041 & SF-042)
- p. Fire Alarm and/or Notification Work (if applicable) with SFMO Material Certification Form (SF-035)
- q. Hood Ventilation and Suppression Work (if applicable) with SFMO Material Certification Form (SF-205)
- r. HVAC Testing with Smoke Bomb (if applicable – HVAC smoke detector is required for any unit over 5 ton or over 2000 cfm on the return side – must be tied into the fire alarm system or if no alarm, then provide w/annunciator panel in a visible location)

For more information, visit our web page listed below and/or questions contact the number listed below.

Web Page: [www.dentoncounty.com/Departments/Emergency-Services/Emergency-Services](http://www.dentoncounty.com/Departments/Emergency-Services/Emergency-Services)

Phone: 940-349-2840

---